

CITY OF MONROVIA
RESULTS LIST
SAMPLE RESULTS
2009

SAMPLE SITE #	LEAD ACTION LEVEL >15ug/l
1	N/D
2	N/D
3	2.4
4	N/D
5	1.7
6	1.5
7	1.3
8	N/D
9	N/D
10	0.52
11	N/D
12	0.51
13	1.5
14	1.4
15	N/D
16	1.8
17	0.53
18	2
19	N/D
20	2.2
21	0.58
22	2.7
23	1.4
24	0.72
25	0.61
26	8
27	0.66
28	0.85
29	N/D
30	0.72
31	N/D

DRL < 5.0 ug/l = 0

ND=Nondetect