

CITY OF MONROVIA  
RESULTS LIST  
SAMPLE RESULTS  
2012

SAMPLE SITE #	LEAD ACTION LEVEL >15ug/l
1	ND
2	ND
3	ND
4	ND
5	ND
6	ND
7	ND
8	ND
9	ND
10	ND
11	14
12	6.4
13	ND
14	ND
15	ND
16	ND
17	ND
18	ND
19	10
20	ND
21	ND
22	ND
23	ND
24	ND
25	ND
26	ND
27	ND
28	ND
29	ND
30	ND
31	13

DRL < 5.0 ug/l = 0

ND = NonDetect