

Level 1

Type of Charging Station(s)

Level 2 – 6.6kW (medium)

Level 2 - 19.2kW (highest)

Level 2 – 9.6kW (high)

Level 2 - 3.3 kilowatt (kW) (low)

CITY OF MONROVIA

Community Development Department Building and Safety Division 415 South Ivy Avenue Monrovia, CA 91016-2888 2022 CALIFORNIA CODES AND CITY OF MONROVIA MUNICIPAL CODE

EFFECTIVE DATE 01/01/2023

1 of 2

Check one

EV Charging Station – Commercial

Eligibility Checklist for Expedited Electric Vehicle Charging Station Permit: COMMERCIAL BUILDINGS

208/240 VAC at 20 or 30 Amps

208/240 VAC at 40 Amps

208/240 VAC at 50 Amps

208/240 VAC at 100 Amps

Power Levels (proposed circuit rating)

110/120 volt alternating current (VAC) at 15 or 20 Amps

Other (provide detail):	Provide rating:		
1. Permit Application Requireme			
A. Does the application include EVCS	manufacturer's specs and installation guidelines?	ΠΥ	
2. Electrical Load Calculation Wo	orksheet:		
A. Is an electrical load calculation worksheet included? (CEC 220)			□N
B. Based on the load calculation worksheet, is a new electrical service panel upgrade required?		ПΥ	ПΝ
1) If yes, do plans include the electrical service panel upgrade?		ΠY	ΠN
C. Is the charging circuit appropriately sized for a continuous load of 125%?		ΠΥ	□N
D. If charging equipment proposed is a Level 2 – 9.6 kW station with a circuit rating of 50 Amps or higher, is a completed circuit card with electrical calculations included with the single line diagram?			□ N
3. Site Plan and Single Line Draw	ing:		
A. Is a site plan and separate electrical plan with a single-line diagram included with the permit application?		ПΥ	ПΝ
If mechanical ventilation requirements are triggered for indoor venting requirements (CEC 625.29 (D)), is a mechanical plan included with the permit application?			ΠN
B. Is the site plan fully dimensioned and drawn to scale?		ΠΥ	ΠN
1) Showing location, size, and use of all structures		ПΥ	ΠN
2) Showing location of electrical panel to charging system		ПΥ	ΠN
3) Showing type of charging system and mounting		ΠY	ΠN
4. Compliance with the 2022 Ca			
A. Does the plan include EVCS manufacturer's specs and installation guidelines?		ΠΥ	
B. Does the electrical plan identify the amperage and location of existing electrical service panel?		ΠΥ	ПN
I) If yes, does the existing panel schedule show room for additional breakers?			
C. Is the charging unit rated more than 60 amps or more than 150V to ground?		ПΥ	
 If yes, are disconnecting means provided in a readily accessible location in line of site and within 50' of EVCS. (CEC 625.23) 			ПΝ
within 50' of EVCS. (CEC 625.2)	3)	ΠΥ	



CITY OF MONROVIA

Community Development Department Building and Safety Division 415 South Ivy Avenue Monrovia, CA 91016-2888 CODE CYCLE

2022 CALIFORNIA CODES

AND CITY OF MONROVIA

MUNICIPAL CODE

EFFECTIVE DATE 01/01/2023

2 of **2**

EV Charging Station – Commercial

D. Does the charging equipment have a Nationally Recognized Testing Laboratory (NRTL) approved listing mark? (UL 2202/UL 2200)	ПΥ	ПИ
E. If trenching is required, is the trenching detail called out?	ПΥ	ΠN
1) Is the trenching in compliance with electrical feeder requirements from structure to structure? (CEC 225)	ПΥ	ПΝ
 Is the trenching in compliance with minimum cover requirements for wiring methods or circuits? (18" for direct burial per CEC 300) 	ПΥ	ПΝ
5. Compliance with the 2022 California Green Building Standards Code (CGBSC):		
A. Do the CAL Green EV Readiness installation requirements apply to this project?	ΠY	ПИ
Do the plans demonstrate conformance with CGBSC Table 5.106.5.3.3 for the minimum required number of charging spaces?	ПΥ	ПΝ
2) Do the construction plans comply with the design requirements set forth in CGBSC 5.106.5.3.1 for single charging spaces or CGBSC 5.106.5.3.2 for multiple charging spaces?	ПΥ	□N
6. Compliance with 2022 California Building Code, Chapter 11-B for Accessibility F	eature	es:
B. Do the plans clearly depict all required accessible EVCS features for the disabled?	ПΥ	ПΝ
Do the plans identify the correct number and type of accessible EVCS stalls required in accordance with Table 11B-228.3.2.1?	ПΥ	ПΝ
2) Do the plans detail compliance with the accessible EVCS features required by 11B-812 and Figure 11B-812.9?	ПΥ	ПΝ
Notes: This criteria is intended for an expedited EVCS permitting process. If any is checked NO, you may revise plans to fit within the eligibility checklist or of the permit application may go through the standard plan review and process. Electrical plans shall be completed, stamped and signed by a California Lie Electrical Engineer or a C-10 electrical contractor.	otherw appro	vise val
Project Address:		
Applicant Signature:		
Applicant Printed Name:		
Contractor's License number and type:		